



OSAGE COUNTY RURAL WATER DISTRICT #15
1500 WEST ROGERS BLVD P.O. BOX 1029
SKIATOOK, OK 74070
(918) 396-2552
(918) 396-2710 FAX
www.rwd15.com

SERVICE CROSSING

Road Bore Requirements

1. Customer must apply for a Utility Permit from the county, if said road is a County road.
2. The casing depth must be at least 36" from the bottom of the ditch, and casing must be across ditch on both sides
3. The District **must** be notified at the start of the bore.
4. The bore is subject to District inspection and approval.
5. The District will install the service line through the conduit and make the tie-in.
6. Spacer blocks must be used.

Customer Signature

Date